


LINTEL NOTES:

- FINAL BEAM SIZE, REINFORCEMENT, AND CONFIGURATION TO BE DESIGNED BY WALL DESIGN ENGINEER
- LINTEL BEAMS SHALL BE PRECAST WITH MINIMUM 7 DAYS CURE
- HEIGHT OF BEAM SHALL CORRESPOND TO HEIGHT OF MODULAR UNITS
- PLACEMENT OF LINTEL BEAMS SHALL BE CONSISTENT WITH THE PLACEMENT OF OUTFALL PIPE
- INSTALL OUTFALL PIPE PRIOR TO CONSTRUCTION OF WALL ABOVE
- OUTFALL PIPE SHALL EXTEND BEYOND BASE COURSE OF WALL NO LESS THAN 6"
- GEOTEXTILE FABRIC SHALL BE INSTALLED AROUND PIPE OPENING
- LINTEL TO EXTEND MINIMUM 18" EITHER SIDE OF PIPE



WALL W/ PIPE PENETRATION

SQUARE FOOT UNIT-SECTION
SCALE: NONE

WALL W/ PIPE PENETRATION

SQUARE FOOT UNIT-PROFILE
SCALE: NONE

THESE PRELIMINARY DETAILS ARE INTENDED AS AN AID IN DESIGNING ATTRACTIVE, DURABLE RETAINING WALLS WITH VERSA-LOK UNITS. FINAL DETERMINATION OF THE SUITABILITY OF ANY INFORMATION OR MATERIAL FOR THE USE CONTEMPLATED, AND ITS MANNER OF USE, IS THE SOLE RESPONSIBILITY OF THE USER. A FINAL PROJECT SPECIFIC DESIGN SHOULD BE PREPARED BY A QUALIFIED, LICENSED, PROFESSIONAL ENGINEER.



VERSA-LOK[®]
Retaining Wall Systems
(800)770-4525 fax(651)770-4089
6348 Hwy36 Ste1, Oakdale, MN 55128 **Solid Solutions[™]**

VERSA-LOK SQUARE FOOT DETAILS

REINFORCED TYPICAL SECTION

SCALE:	3/8"=1'
DRAWN BY:	PPS
CHECKED BY:	
DATE:	10/2007
DWG. NO.	of reinforced section